

Certificate of constancy of performance



according to Regulation (EU) 2024/3110

Certificate No.: 1008-CPR-MC 69266264 0004

Report No.: HU22612G 003

Applicant: Hangzhou Hikfire Technology Co., Ltd.
Room 311, Unit B, Building 2, No.399, Danfeng Road,
Binjiang District, Hangzhou City, Zhejiang Province, China

Manufacturer: Hangzhou Hikfire Technology Co., Ltd.
Room 311, Unit B, Building 2, No.399, Danfeng Road,
Binjiang District, Hangzhou City, Zhejiang Province, China

Manufacturing plant: Hangzhou Hikvision Electronics Co., Ltd.
No. 299, Qiushi Road, Tonglu Economic Development Zone,
Tonglu County, 311500 Hangzhou, China

Product: Smoke Alarm

Identification: HF-S2, HF-S2E, HF-Y2, HF-Y2E, HS-S2, HS-S2E, HS-Y2,
HS-Y2E, NP-Y2-S, NP-Y2 House hold Smoke Alarm
Intended use: Fire Safety

FPC Report No.: HU25J1RX 001
Test Report No.: CN22ACGJ 001

System of assessment and verification: 1

Tested according to: EN 14604:2005
EN 14604:2005/ AC:2008

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performance described in Annex of the above standard(s) under above system are applied and the product fulfils all the prescribed requirements set out above.
This certificate was first issued on 2022-09-07 and it will remain valid until the test methods and/or factory production control requirements included in the standard, used to assess the performance of the declared characteristics, and the product, and the manufacturing conditions in the plant are unchanged.
The manufacturing plant and factory production control system of the manufacturer is supervised regularly by the Certification Body.

Certification Body

Date of issue:
Budapest, 2025-11-26

Handwritten signature of László Kocsis in blue ink.
László Kocsis

TÜV Rheinland InterCert Kft., Product Certification Body — H-1143 Budapest, Gizella út 51-57. — www.tuv.com
Product certification body accredited by NAH under No NAH-6-0053/2023/K, Notified Body No. 1008

Validity of certificate can be checked on www.CERTIPEDIA.com

Essential characteristics	Performance	Harmonised technical specification
Operational reliability	Pass	<p>EN 14604:2005 EN 14604:2005/AC:2008</p>
Repeatability	Pass	
Directional dependence	Pass	
Initial sensitivity	Pass	
Air movement	Pass	
Dazzling	Pass	
Dry heat (55±2°C, 2h)	Pass	
Cold (operational) (0±2°C, 2h)	Pass	
Damp heat (operational) (40±2°C, 93±3%, 4 days)	Pass	
Sulphur dioxide (SO ₂) corrosion (25 °C; 93 %; 25 ppm; 4 days)	Pass	
Impact (1,9±0,1 J; 1 time)	Pass	
Vibration (operational) (10 to 150 Hz; 5m/s ² ; 3 axes)	Pass	
Vibration (endurance) (10 to 150 Hz; 10m/s ² ; 3 axes)	Pass	
Electromagnetic Compatibility (EMC), Immunity tests (operational)	Pass	
Fire sensitivity (TF2; TF3; TF4; TF5)	Pass	
Battery fault warning	Pass	
Sound output	Pass	
Sounder durability	Pass	
Inter-connectable smoke alarms	N/A	
Alarm silence facility	Pass	
Variation in supply voltage	Pass	
Battery reversal	Pass	
Back-up power source	N/A	
Electrical safety	Pass	

Certification Body

Date of issue:

Budapest, 2025-11-26



László Kocsis